

AIR BOSS® MODEL 75 & ATS SERIES



Maintenance Quick Checks

WEEKLY

- Ensure detergent level is above fill line in wash tank; never allow detergent level to get below the Low Level Line. Use only concentrated detergent, TRIDEX ESP1000 - DO NOT DILUTE.
- Visually check power supply LED operation on control panel.
Continuous flickering lights indicate arcing in cells and troubleshooting/service may be required.
- Check to ensure unit is washing at specified time on the 7-day clock.

MONTHLY

- Ensure water pressure is 40-60 psi at full flow when unit is washing.
- Manually check complete wash cycle operation with control schematics.

SEMI-ANNUALLY

- Remove and manually clean pre- and after-filters, ionizing/collecting cells and spiked ionizer tips. Cells must be completely dry before installing.
- Inspect wash nozzle spray pattern for clogged or missing nozzles.
- Inspect manifold drive motor, linkage and drain for proper operation.
- Inspect and replace carbon trays as required.
- Inspect and replace media/bag filters (if provided).
- Lubricate blower bearings (if provided).
- Remove and clean water line strainer.
- Inspect fire suppression system (if provided).

ANNUALLY

- Fire suppression system to be inspected and certified by responsible agency.

*NOTE: Refer to the **Operations & Service Manual** for detailed maintenance instructions and operating tips.*



FEDDERS ENGINEERED PRODUCTS

101 McNeill Road · Sanford, NC 27330

Phone: 800-884-0002 · Fax: 800-458-2379 · www.trioninc.com · email: sales@trioninc.com